

**STATE OF NEW HAMPSHIRE
BUILDING CODE REVIEW BOARD**

**PART Bcr 307 CHANGES OR UPDATES TO THE NATIONAL ELECTRICAL CODE
2008**

Effective July 1, 2008

Bcr 307.1 National Electrical Code 2008

- (a) Pursuant to RSA 155-A:10, V, the board hereby adopts the following changes and updates to the applicable provisions of the National Electrical Code 2008.
- (1) Effective July 1, 2008, the National Electrical Code 2005 is replaced with the National Electrical Code 2008.
- (2) Effective July 1, 2008, amend section 210.5(C) of the National Electrical Code 2008 by replacing said section with the following:

Ungrounded Conductors. Where the premises wiring system has branch circuits supplied from more than one nominal voltage system, each ungrounded conductor of a branch circuit shall be identified by system at all terminations, connection, and splice points. The means of identification shall be permitted to be by separate color coding, marking tape, tagging, or other approved means. The method utilized for conductors originating within each branch-circuit panelboard or similar branch-circuit distribution equipment shall be documented in a manner that is readily available or shall be permanently posted at each branch-circuit panelboard or similar branch-circuit distribution equipment.